

**EXHIBIT 2**  
**Violations of NPDES Permit Effluent Limitations**

<b>Dominion Site</b>	<b>Permit Number</b>	<b>Violation Description</b>	<b>Date</b>	<b>Limit</b>	<b>Result</b>
Chesapeake Energy Center	VA0004081	Effluent Violation – Total Suspended Solids Outfall 002	04/06/2016	50 mg/l	56 mg/l
Chesterfield Power Station	VAG830470	Effluent Violation – Total Petroleum Hydrocarbons Outfall 001	04/07/2015	15 mg/l	60 mg/l
Chesterfield Power Station	VA0004146	Permit Limit-Total Recoverable Selenium-Quantification Level	03/10/2017		
Clover Power Station	VA0083097	Effluent Violation – Total Recoverable Manganese Outfall 009	12/12/2013	50 ug/l	59.65 ug/l
Clover Power Station	VA0083097	Effluent Violation – Total Suspended Solids Outfall 002	3/31/2014	50 mg/l	176.5 mg/l
Mt. Storm Power Station	WV0005525	Effluent Violation – Total Ammonia Nitrogen Outfall 421	3/23/2016	15 mg/l	24.5 mg/l
Mt. Storm Power Station	WV0005525	Effluent Violation – Total Ammonia Nitrogen Outfall 421	3/23/2016	30 mg/l	36.1 mg/l
Altavista Power Station	VA0083402	Effluent Violation – pH Outfall 001	3/10/2016	9.0	9.73